

No. C-MET/HD/SP-41/DGSET/10/2019-20/11705

Date: 11.03.2020

Corrigendum

PROCUREMENT OF 200 KVA DIESEL GENERATOR SET

Tender Ref. No.: C-MET/HD/SP-41/DGSET/10/2019-20/11620 dated 11.02.2020

Sr. No.	Query/clarification	Remark/reply
1	Please confirm foundation for DG in CMET scope or bidder scope.	Foundation design/layout has to be provided by bidder. Civil work related to lying the foundation will be carried out by C-MET.
2	Please confirm supply, laying and termination of power and control cables in CMET scope or bidder scope. If bidder scope, please confirm the total length of power and control cable.	Supply, laying and termination of power and control cables has to be in bidder scope. Total length of power and control cable is 15 meters each.
3	Please confirm the total height of exhaust stack.	Total height of exhaust stack required is 12 meters as per recommended. Kindly correct it to 12 meters instead of 2.5 meters as specified in specifications.
4	Manufacturer not recommended for space heater, RTD for your location. Please confirm your acceptance.	Space Heaters and Winding & Bearing RTDs are required for alternator. Crank case heater is required for engine.
5	Please confirm CEA / State Gov approval is required or not. If required, please confirm who will pay the necessary fees to authority.	Yes. Required. Fee can be paid by C-MET.
6	We are MSME & NSIC registered organization. Copies of certificates attached. Kindly confirm eligibility of EMD exemption. Also please confirm EMD amount.	EMD exempted in such case.

The other terms & conditions of the tender document remain same & unaltered.

Administrative Officer

11/03/2020